

**QUICK START REFERENCE:
BD70CC-1 / 1.0CF TURBIDITY REMOVAL SYSTEM WITH BACK
WASH CONTROL (110 OR 220 VOLT)**

*The time must display 12:01 pm to enter programming (pm must be visible)

- 1) Press and hold the up and down arrows for 6 seconds until the display shows **DF GAL (units of measure gallons)**
 - 2) Push cycle – use the up key to display **VT-Filtr (valve type filter)**
 - 3) Push cycle – use the up key to display **CT-tc (Cycle type time clock)**
 - 4) Push cycle – use the up key to display **NT-1 (number of tanks 1)**
 - 5) Push cycle – use the up key to display **TS-U1 (Tank in service 1)**
 - 6) Push cycle – use the up key to display **DO-7 (day override –frequency of regeneration 7 days)**
 - 7) Push cycle – use the up key to display **BW-10 (back wash 7 minutes)**
 - 8) Push cycle – use the up key to display **RR- 8 (rapid rinse 8 minutes)**
 - 9) Push cycle – the valve will reprogram itself and return to time of day and day countdown.
- Please enter programming again and check to see that all settings are as described above.
- Most of the screens shown in the manual will not be visible as they are for other valve types.